

DECLARATION OF PARAMETERS

No. 01/24

1. Product type and trade name: **Fire shutter with folding stairs LUSO PP/ LSF**
2. Type, batch number or serial number for identification of the construction product: **JAP 400 LUSO PP or LSF**
700 x 500 to 1200 x 700 mm
3. Specified Slovak standard relating to the product:
STN 74 6481:2000, STN 74 6481:2000/Z1:2003, STN 74 6481:2000/Z2:2006
4. SK technical review:
5. Intended use of product:
 - The product is used as a fire shutter for closing inspection openings in installation, elevator, electrical installation shafts, etc., or as a fire shutter for ceilings of family houses, residential, administrative and multifunctional buildings.
 - The product is used as a permanent closure with occasional opening (during repair or inspection of technical or technological equipment) with the exception of a fire shutter built into the ceiling of a family house.
6. Commercial name, headquarters address, org. ID of manufacturer and place of production:
JAP FUTURE s.r.o.
Nivky 67, 750 02 Přerov III – Lověšice, Czech Republic
Org. ID: 05533139
7. Name and address of authorized representative as established: -
8. System of parameter assessment applied according to decree **MDVRR SR No. 162/2013 Coll.: system I**
9. SK certificate indicator and date of issuance, if issued, and name of issuing authorized body:
SK CERTIFICATE on the permanency of parameters for the construction product's essential properties No. SK01-ZSV-0408
(date of issuance 18.12.2023) – **FIRES, s.r.o., Osloboditeľov 282, 059 35 Batizovce, Slovensko, authorized body SK01.**

10. Declared parameters

Essential properties	Parameters	Testing protocol	Test laboratory
Type of construction element	D2		
Self-closing in case of fire	No parameter established (infrequent opening and closing of the product after each opening is assumed)	Determination of product type No. C01/07/005/2801/SC	FIRES, s.r.o. Osloboditeľov 282 059 35 Batizovce Slovak Republic
Product construction	Product contains no sharp edges or joints. Risk of injury or damage to clothes during contact with the product is minimal.		
Fire resistance	El ₁ 60/El ₂ 60/EW 60	PO testing protocol Pr-20-2.132n Fire classification certificate PKO-20-082	PAVUS, a.s. Prosecká 412/74 190 00 Prague 9 Czech Republic

11. The manufacturer declares that the product defined in points 1 and 2 has the parameters of the essential properties indicated under point 10.
12. This declaration of parameters is issued under the exclusive responsibility of the manufacturer indicated in point 6.

In Přerov, 12. January 2024

PaedDr. Petr Paksi, DBA
Company executive

JAP FUTURE s.r.o.
Nivky 67, 750 02
Přerov III – Lověšice

+420 581 587 811
jap@japcz.cz
japcz.cz

IČO 05533139
DIČ CZ05533139
Spisová značkaC 75573
Krajský soud v Ostravě